



Sorrento Retirement Residence, located in downtown Bolton, with the 140 stunning suites, beautifully appointed amenities and unparalleled service.

Requirements:

- Pull Cords in each suite
- Smoke Detector in each suite
- Pendants for the tenants, with the visual and audio alerting
- Video Intercoms in different zones
- Surveillance System and monitoring
- Access control with the central Management
- EMS with the automated recurring reports
- Alarms Live Panels for the receptionist and staff stations
- Phone system in the multitenant mode (NCS, Management and Tenants)

Equipment Provided by Controlledcare:


- Phone System on premise with the multiple layer support, not limited in any way
- Desk phones, Mobile wireless phones and SIP trunking
- Event Management Server (EMS) with the reporting, monitoring, Live Panels and Push notifications
- Access Control Solution with the central management of the areas, elevators and doors
- Surveillance System with the video analytics and full space recordings
- Wireless Pendants with the audio and visual alerting
- Pull Cords, Advanced I/O controllers for each floor and network switches
- Door Intercoms with the video and remote door control
- Positioning points for each level and areas

Solution and integrations provided:

- Nurse Call System with the location and alarm positioning option
- Automated Reports per requirement, scheduled every Monday at 08:00AM, in total 3
- Analytic on request with the filtering and sorting options, exported to PDF or Excel
- Remote access to Web Portal through any type of browser
- Alarms Live Panel Screen Super HD with the history frame
- Nurse Call Activity, Staff efficiency and patient care evidence
- NCS integrated to Phone System, Door Intercom and Fire Alarm
- Phone System with three levels: Tenants, NCS and Management
- Access Control multifunctional and central management
- Escalated Alarms, Nurses on shift, Master Nurse, General Manager
- Video Door Intercom integrated with PBX and NCS
- Added to the 24/7 monitoring system for advanced system notifications







Administrator System Level

VANTACT

Call History

1 2 3 4 5 » 10 Suite 307 Start End

<input type="checkbox"/>	Start	From	To	Duration	Trunk
6/3/2021					
<input type="checkbox"/>	12:34:39 PM	"Suite 307" <sip:suite-307@10.2.71.150>	"NCS Hunt" <sip.ncshunt@10.2.71.150>	00:21	
<input type="checkbox"/>	12:34:39 PM	"Suite 307" <sip:suite-307@10.2.71.150>	"NCS Hunt" <sip.ncshunt@10.2.71.150>	00:01	
<input type="checkbox"/>	12:34:19 PM	"Suite 307" <sip:suite-307@10.2.71.150>	"NCS Hunt" <sip.ncshunt@10.2.71.150>	00:01	
<input type="checkbox"/>	12:33:19 PM	"Suite 307" <sip:suite-307@10.2.71.150>	"NCS Hunt" <sip.ncshunt@10.2.71.150>	00:08	
<input type="checkbox"/>	12:28:09 PM	"Suite 307" <sip:suite-307@10.2.71.150>	"NCS Hunt" <sip.ncshunt@10.2.71.150>	00:12	
<input type="checkbox"/>	2:39:25 AM	"Suite 307" <sip:suite-307@10.2.71.150>	"NCS Hunt" <sip.ncshunt@10.2.71.150>	00:17	
<input type="checkbox"/>	12:03:48 AM	"Suite 307" <sip:suite-307@10.2.71.150>	"NCS Hunt" <sip.ncshunt@10.2.71.150>		

Delete CSV

Analytics Peripheral Report

Facility: Bolton

Time Period: 5/30/2021 12:00 AM - 6/5/2021 12:00 AM

Name	Battery Level	Date
BUTTON-314	3852.935(73.3%)	6/4/2021
BUTTON-319	4073.132(90.2%)	6/4/2021
BUTTON-203	4200.803(100%)	6/4/2021
BUTTON-510	4245.88(100%)	6/4/2021
BUTTON-210	4325.56(100%)	6/4/2021
BUTTON-510	4191.241(99.3%)	6/3/2021
BUTTON-510	4199.894(100%)	6/2/2021
BUTTON-314	3941.27(80.1%)	6/2/2021
BUTTON-314	3991.357(84%)	6/1/2021
BUTTON-307	3995.3(84.3%)	6/1/2021
BUTTON-510	4210.822(100%)	6/1/2021
BUTTON-210	4418.97(100%)	6/1/2021
BUTTON-314	4066.482(89.7%)	5/30/2021
BUTTON-203	4297.33(100%)	5/17/2021
BUTTON-203	4290.505(100%)	5/15/2021
BUTTON-203	4351.06(100%)	5/14/2021
BUTTON-314	3885.72(75.8%)	5/14/2021
BUTTON-314	4002.738(84.8%)	5/11/2021
BUTTON-314	4086.975(91.3%)	5/9/2021
BUTTON-203	4276.388(100%)	5/8/2021
BUTTON-307	4410.253(100%)	5/5/2021


Master Communicator by ControlledCare.com

Page 1 of 3

Analytics Response Summary Report

Facility: Bolton

Time Period: 5/30/2021 12:00 AM - 6/5/2021 12:00 AM



Control Button	Department	Level #	Area	Bed #	Total Calls	Response Time Avg.
Smoke		5	506		1	14h:49m:58s
Pull		3	307		4	01h:32m:00s
Door	Doors	9	Garage Pedestal		102	00h:00m:50s
Door	Doors	9	Main Door		6	00h:00m:45s
Door	Doors	9	P1 Garage to Elevator		9	00h:00m:45s
Door	Doors	9	P1 Garage to Hallway		35	00h:00m:45s
Door	Doors	9	Roof 6		2	00h:00m:45s



9 LEVEL DOORS

GARAGE PEDESTAL

Activated: 06/05/2021 12:01:12 PM

00h:00m:39s ago



- DOOR - DOORS LEVEL 9 P1 GARAGE TO HALLWAY
 Activated: 06/05/2021 11:23:28 AM
 Canceled: 06/05/2021 11:24:13 AM
 Response: 00h:00m:45s 00h:37m:37s ago
- DOOR - DOORS LEVEL 9 P1 GARAGE TO HALLWAY
 Activated: 06/05/2021 11:14:01 AM
 Canceled: 06/05/2021 11:14:46 AM
 Response: 00h:00m:45s 00h:47m:05s ago
- DOOR - DOORS LEVEL 9 GARAGE PEDESTAL
 Activated: 06/05/2021 08:53:33 AM
 Canceled: 06/05/2021 08:53:53 AM
 Response: 00h:00m:50s 03h:07m:53s ago
- DOOR - DOORS LEVEL 9 ROOF 6
 Activated: 06/04/2021 08:07:12 PM
 Canceled: 06/04/2021 08:07:57 PM
 Response: 00h:00m:45s 15h:53m:53s ago
- 🔔 PANIC BUTTON - LEVEL 2 BUTTON-210
 Activated: 06/04/2021 07:41:38 PM
 Canceled: 06/04/2021 07:41:40 PM
 Response: 00h:00m:04s 16h:20m:11s ago
- 🔔 PANIC BUTTON - LEVEL 2 BUTTON-210
 Activated: 06/04/2021 07:41:33 PM
 Canceled: 06/04/2021 07:41:33 PM
 Response: 00h:00m:14s 16h:20m:18s ago
- 🔔 PANIC BUTTON - LEVEL 5 BUTTON-510
 Activated: 06/04/2021 07:21:10 PM
 Canceled: 06/04/2021 07:21:13 PM
 Response: 00h:00m:03s 16h:40m:37s ago
- 🔔 PANIC BUTTON - LEVEL 2 BUTTON-203
 Activated: 06/04/2021 08:45:30 PM
 Canceled: 06/04/2021 08:46:07 PM



- DOOR - DOORS LEVEL 9 P1 GARAGE TO HALLWAY
 Activated: 06/05/2021 11:23:28 AM
 Canceled: 06/05/2021 11:24:13 AM
 Response: 00h:00m:45s 00h:25m:46s ago
- DOOR - DOORS LEVEL 9 P1 GARAGE TO HALLWAY
 Activated: 06/05/2021 11:14:01 AM
 Canceled: 06/05/2021 11:14:46 AM
 Response: 00h:00m:45s 00h:35m:14s ago
- DOOR - DOORS LEVEL 9 GARAGE PEDESTAL
 Activated: 06/05/2021 08:53:33 AM
 Canceled: 06/05/2021 08:53:53 AM
 Response: 00h:00m:50s 02h:56m:06s ago
- DOOR - DOORS LEVEL 9 ROOF 6
 Activated: 06/04/2021 08:07:12 PM
 Canceled: 06/04/2021 08:07:57 PM
 Response: 00h:00m:45s 15h:42m:02s ago
- 🔔 PANIC BUTTON - LEVEL 2 BUTTON-210
 Activated: 06/04/2021 07:41:38 PM
 Canceled: 06/04/2021 07:41:40 PM
 Response: 00h:00m:04s 16h:08m:20s ago
- 🔔 PANIC BUTTON - LEVEL 2 BUTTON-210
 Activated: 06/04/2021 07:41:33 PM
 Canceled: 06/04/2021 07:41:33 PM
 Response: 00h:00m:14s 16h:08m:27s ago
- 🔔 PANIC BUTTON - LEVEL 5 BUTTON-510
 Activated: 06/04/2021 07:21:10 PM
 Canceled: 06/04/2021 07:21:13 PM
 Response: 00h:00m:03s 16h:28m:46s ago
- 🔔 PANIC BUTTON - LEVEL 2 BUTTON-203
 Activated: 06/04/2021 08:45:30 PM
 Canceled: 06/04/2021 08:46:07 PM
 Response: 00h:01m:17s 17h:03m:12s ago
- DOOR - DOORS LEVEL 9 GARAGE PEDESTAL
 Activated: 06/04/2021 08:32:10 PM
 Canceled: 06/04/2021 08:33:01 PM
 Response: 00h:00m:51s 17h:16m:59s ago
- DOOR - DOORS LEVEL 9 GARAGE PEDESTAL
 Activated: 06/04/2021 08:29:58 PM